



euroclima®



Climatix IC Cloud Services

Fernzugriff!

Remote control!

Accesso remoto!



ET 177-0

Your system is equipped with
the following option:

Climatix IC

- 1) Connect network cable with internet access to the "Ethernet"-Port from the Siemens controller (POL638/POL648)
- 2) Release the port 443 (https) on the local network
(Server: <https://clx.ccl.climatixic.com>)
- 3) Adapt the IP-settings in the menu "All settings -> Configuration -> Communication Controller -> IP config." to the local network settings
- 4) Restart the controller and check if in the Info-menu below Climatix-IC the points "Communication" -> "Ok" and "Cloud server" -> "Connected" (if not, there is a problem in the local network)
- 5) Send following informations to the Euroclima contact (the cloud access will be activated timely):
 - Activate code (in Info-menu below Climatix-IC)
 - Building address where the unit is located
 - E-Mail addresses + User level which should have access

Date	07.05.24	Kunde
Draw.	MaWi	
A	In Bearbeitung	16.07.24wscad01
Status	rev.	Date Nom Norm



Climatix IC

Position	=
Positionsnummer	+
Project pages	Projektnummer
Total 1	Projektbezeichnung
actual 1	Sheet 1
	von 1Bl.