euroclima®

Climatix IC Cloud Services

Fernzugriff!
Remote control!
Accesso remoto!

ET 177-0

Votre système est équipé de loption suivante:

Climatix IC

1) Connect network cable with internet access to the “Ethernet”-Port from the Siemens controller (POL638/POL648)

2) Release the port 443 (https) on the local network
(Server: https://clx.ccl.climatixic.com)

3) Adapt the IP-settings in the menu “All settings -> Configuration -> Communication Controller -> IP config.” to the local network settings

4) Restart the controller and check if in the Info-menu below Climatix-IC the points “Communication” -> “Ok” and “Cloud server” ->“Connected” (if not, there is a problem in the local network)

5) Send following informations to the Euroclima contact (the cloud access will be activated timely):
- Activate code (in Info-menu below Climatix-IC)
- Building address where the unit is located
- E-Mail addresses + User level which should have access.

				Date	07.05.24	Kunde	euroclima® We care for better air...	Climatix IC	Position	=	
				Gez.	MaWi				Positionsnummer	+	
A	In Bearbeitung	16.07.24	wscad01	Test.					Feuille Total 1 Actuel 1	Projektnummer / Projektbezeichnung	Folio 1 von 1Bl.
État	Variation	Date	Nom	Norm							